

FIN-002 INTERIM RESULTS 171114

FIN-002 Tilt n' Turn - DG

ID	Name	Glazing Name	Glazing ID	U _w	SHGC _w	Tvis _w
1	FIN-002-001-01-6SCAz-8Ar-4	6SCAz-8Ar-4	8338	2.5	0.16	0.17
2	FIN-002-002-01-638CPGy-8Ar-4	638CPGy-8Ar-4	8339	1.9	0.31	0.25
3	FIN-002-003-01-5-10Ar-4	5-10Ar-4	4690	2.4	0.53	0.57
4	FIN-002-004-01-6-8Ar-6ET	6-8Ar-6ET	10081	1.9	0.48	0.52
5	FIN-002-005-01-4-12Ar-4	4-12Ar-4	4781	2.4	0.55	0.58
6	FIN-002-006-01-4Gy-12Ar-4ET	4Gy-12Ar-4ET	10099	1.7	0.36	0.33
7	FIN-002-006-02-4-12Ar-4ET	4-12Ar-4ET	10101	1.7	0.51	0.53
8	FIN-002-007-01-5-10Ar-5	5-10Ar-5	4731	2.4	0.52	0.57
9	FIN-002-008-01-5Gy-10Ar-5ET	5Gy-10Ar-5ET	10056	1.8	0.32	0.28